

**EX. 10**



P.O. Box 1175 • Lewisville, TX 75067 • Phone: (972) 219-1001 • Toll-Free: (866) 311-9940 • Fax: (972) 219-1002

911 E. Highway 121 Business • Lewisville, TX 75057

May 21, 2014

Mr. Thomas Leach  
Supervisor, Testing Technologies  
OG + E Electric Services  
321 North Harvey  
Oklahoma City, Oklahoma 73101

RE: Preliminary Results for Muskogee Unit No. 6

Dear Mr. Leach:

The results from the testing that was performed on Muskogee Unit No. 6 on April 29 and 30, 2014 are attached. If you have any questions, please do not hesitate to contact me.

Sincerely,

A handwritten signature in blue ink that reads "Billy J. Mullins, Jr." in a cursive script.

Billy J. Mullins, Jr., PE, QSTI, QEP, DEE

President

**Muskogee Unit No. 6 Preliminary Results**

<u>Run No.</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
>PM10:				
Lbs/hr	0.0	1.3	0.0	0.4
Lbs/mmbtu	0.0000	0.0003	0.0000	0.0001
<PM10>PM2.5:				
Lbs/hr	65.4	39.8	80.5	61.9
Lbs/mmbtu	0.0122	0.0077	0.0154	0.0118
<PM2.5:				
Lbs/hr	5.2	17.4	8.8	10.5
Lbs/mmbtu	0.0010	0.0034	0.0017	0.0020
CPM:				
Lbs/hr	147.9	116.7	113.3	126.0
Lbs/mmBtu	0.0276	0.0226	0.0216	0.0239
Total:				
Lbs/hr	218.5	175.2	202.6	198.8
Lbs/mmbtu	0.0408	0.0340	0.0387	0.0378